SIEMENS

Product data sheet 3LD2022-0TK13



MAIN/EMERG. STOP SWITCH 3-POLE IU=16, P/AC-23A AT 400V=7.5KW FRONT MOUNTING FOUR-HOLE MOUNTING KNOB-OPERATED MECHANISM RED/ YELLOW (EMERG. STOP)

Similar to image

product brand name		SENTRON
Product designation		Main and EMERGENCY-STOP switches
Design of the operating mechanism		knob-operated mechanism, red/yellow
Type from device		fixed mounting
Protection class IP		IP65
Number of poles		3
Mounting type		front mounting
• front mounting		Yes
• rail mounting		No
• series installation		Yes
Insulation voltage / rated value	V	690
Continuous current / rated value	А	16
Product equipment / interlock		Yes
Design of the electrical connection		
• for auxiliary contact		connection terminals
• for main current circuit		connection terminals
Type of the driving mechanism / motor drive		No
Number of NC contacts / for auxiliary contacts		0

Impulse voltage resistance / rated value	V	6,000
Number of NO contacts / for auxiliary contacts		0
Number of changeover contacts / for auxiliary contacts		0
Operating current / at AC-21 / rated value	А	16
Operating voltage		
• of the auxiliary contacts / for AC / maximum	٧	500
• at 50/60 Hz / for AC / rated value	V	690
Service power / at AC-3		
• at 400 V / rated value	kW	5.5
• at 690 V / rated value	kW	5.5
Short-time current resistance (lcw) / at 690 V / limited to 1 s / rated value	А	340
Depth	mm	89.5
Height	mm	66
Width	mm	49
Mechanical operating cycles as operating time / of the main contacts / typical		100,000
Active power loss / per conductor / typical	W	0.5
Design of the fuse link / for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 10 A
Conductor cross section that can be connected		
• for main contacts		
• single- or multi-stranded	mm²	1 6
• stranded	mm²	1 6
• stranded wire / with conductor end processing / maximum	mm²	4
• for auxiliary contacts		
• finely stranded		
 with conductor end processing 	mm²	0.75 2.5
• single- or multi-stranded	mm²	0.75 4
• stranded	mm²	0.75 4
Type of the connectable conductor cross-section		
for auxiliary contacts / solid		50
 for main contacts / finely stranded / with conductor end processing 		4
• for auxiliary contacts		
finely stranded / with conductor end processing		2x (0.75 1.5 mm2), 1x 2.5 mm2
Ambient temperature / during operating	°C	-25 +55
Protection against electrical shock		finger-safe
Operating cycles / maximum	1/h	50
Acceptability for application		
main switch		Yes

• switch disconnector		Yes
maintenance/repair switch		Yes
safety cut-out switch		Yes
emergency stop switch		Yes
Product extension / optional		
• motor drive		No
voltage trigger		No
Mounting type		
 front mounting with central attachment 		No
• front mounting with 4-hole attachment		Yes
Operating frequency		
• initial value	Hz	50
• final value	Hz	60
Design of the fuse link / for short-circuit protection of the main		fuse gL/gG: 20 A
circuit / necessary		
Service power / at AC-23 A		
at 400 V / rated value	kW	7.5
at 690 V / rated value	kW	7.5
Insulation voltage / of the auxiliary switch / rated value	V	500
Continuous current / of the auxiliary contact / rated value	Α	10
Item designation		
according to DIN EN 61346-2		S

Certificates/approvals:

General Product Approval

<u>(P</u>





Special Test Certificate

Test Certificates



Shipping Approval

GL

other

Declaration of Conformity

other

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

 $\underline{\text{https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3LD2022-0TK13}}$

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

 $\underline{\text{http://support.automation.siemens.com/WW/view/en/3LD2022-0TK13/all}}$

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3LD2022-0TK13

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

Datanorm GAEB81 GAEB83 RTF TXT



last change: Jul 14, 2014